



Jim Doyle, Governor  
Jack L. Fischer, A.I.A., Secretary

August 26, 2008

REVISED COPY

DEMA ENGINEERING CO.  
ENGINEERING  
SONE CHAN  
10020 BIG BEND BLVD.  
ST. LOUIS MO 63122

Re: Description: PROPORTIONER  
Manufacturer: DEMA ENGINEERING CO.  
Product Name: BLEND CENTERS  
Model Number(s): 633AG-1, 633AG-4, 635AG-1, 635AG-4, 637AG-1, 637AG-4, 639AG-1, 639AG-4, 661AG-4, 661AGB, 661AGDB, 662-AG-1, 662-AG-4, 662-2AGDB-11, 662-2AGDB-14, 662-2AGDB-44, 662-2AG-11, 662-2AG-14, 662-2AG-44, 662-3AG-1, 662-3AG-114, 662-3AG-144, 662-3AG-4, 662-4AG-1111-2, 662-4AG-1114-2, 662-4AG-1144-2, 662-4AG-1111-4, 662-4AG-1114-4, 662-4AG-1144-4, 662-635AG-1, 662-635AG-4, 662-637AG-1, 662-637AG-4, 662-639AG, 681AG-1, 681AG-2, 681AG-3, 681AG-4, AND 681AG-5  
Product File No: 20050797

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.41 (3) (a) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of November 2010.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must be installed with the pressure indicating tee permanently attached to the inlet of the supply hose serving this product.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: Jerry.Thompson@wi.gov